

# SIL



## Functional Safety Certificate

No. 0P230331.NUC74

**Certificate's Holder:** NUTORK CORP.  
5<sup>th</sup> Floor, Building 4, No. 530, Zhaojiajing Road, Chedun Town, Songjiang District, Shanghai

**Product:** Electric Actuator  
**Model(s):** NTE-xxx, NTQ-xxxx, NTK-xxx, NTR-xxx, NTM-xxx-xxx

**Standard:** Has been assessed per the relevant requirements of:  
IEC 61508 Parts 1-7:2010, IEC 60664-1:2007, IEC 61511-1:2003+Carr.1:2004, IEC 61326-3-1:2008

And meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A Element

SIL 2 @ HFT= 0; SIL 3@ HFT=1; Route 2h

\* Safety function:

Electric Actuator with configurable safety functions: Stay put or Emergency shut-down (ESD) open or close on demand.

\*Specific requirements:

The instructions of the associated Installation and Operating Manual shall be considered.

\* Is suitable to be safety function according to the description and the configuration defined in Annex I.

**Verification Mark:**



The Verification Mark can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way

**Remark:** This SIL Verification of Compliance has been issued on a voluntary basis. ECM confirms that a Test Report is existent for the above listed product(s) and found to meet the requirements of above standards for application in safety related system up to Safety Level of **SIL 3**. The unit must be properly designed into a Safety Instrument Function as per the requirements in the Safety Manual. The Verification Mark shown above can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way. In addition the Verification's Holder is NOT allowed to transfer the Verification to third parties. This certificate can be checked for validity at [www.entecerma.it](http://www.entecerma.it)

Date of issue 31 March 2023

Expiry date 30 March 2028

For online check:



Approver  
Ente Certificazione Macchine  
Legal Representative  
Luca Bedonni



Ente Certificazione Macchine

Via Cà Bella, 243 - 40053 Valsamoggia Loc. Castello di Serravalle (Bo) Italy  
☎ +39.0516705141 📠 +39.0516705156 ✉ info@entecerma.it 🌐 www.entecerma.it

# Annex I



**No. 0P230331.NUC74**

1. SC 3 (SIL 3 Capability):  
The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.
2. A Safety instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.
3. Random Capability:  
The SIL limit imposed by the Architectural Constraints for each element.
4. IEC 61508 Failure Rates in FIT\*  
For product used in a final element assembly, SIL must be verified for the specific application using the following failure rate data.

Failure rates according to IEC 61508, FIT\*

Model	Failure Category	$\lambda_{sd}$	$\lambda_{su}$	$\lambda_{dd}$	$\lambda_{du}$
	Stay put	0	86	0	5
	ESD Open	220	120	76	3
	ESD Close	206	133	95	3

5. SIL Verification:  
The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of  $PFD_{AVG}$  considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.  
\*FIT=1 failure/10E<sup>9</sup> hours